



*The Good Life*

**NOTES**

1. FIRE HYDRANTS SHALL COMPLY WITH ANSI/AWWA C502 AND SHALL BE MUELLER CO. SUPER CENTURION 250 OR AMERICAN DARLING MARK 73. HYDRANTS SHALL BE STANDARD RED IN COLOR.
2. HYDRANTS SHALL HAVE NATIONAL STANDARD SCREW THREADS AND OPERATING NUT AND ALL VALVES SHALL OPEN BY TURNING COUNTER-CLOCKWISE.
3. CONTRACTOR MAY SUBSTITUTE CONCRETE RESTRAINT BLOCKING AT THE HYDRANT ELBOW WITH MECHANICAL JOINT RESTRAINTS (MEGALUG SERIES 1100). A BLOCK MUST BE INSTALLED TO SUPPORT THE ELBOW.

REVISIONS

NO	DATE	DESCRIPTION

CITY OF TEGA CAY  
LAND DEVELOPMENT  
STANDARDS

STANDARD FIRE HYDRANT

STD. NO	REV