


1. THE INVERT OF THE INLET PIPE SHALL NOT BE LESS THAN 2" ABOVE THE INVERT OF THE OUTLET PIPE.
2. BAFFLE WALL SHALL BE LOCATED 2/3 THE DISTANCE FROM THE INLET SIDE AND 1/3 THE DISTANCE FROM THE OUTLET SIDE
3. THE DEPTH LENGTH DIMENSIONS SHOWN ARE FOR STANDARD 1000 GAL. OR 1500 GAL. PRE CAST TANK . THE EXACT SIZE AND TYPE OF EACH INTERCEPTOR SHALL BE APPROVED BY THE CITY.
4. ALL PIPING SHALL BE DUCTILE IRON, OR SDR*35 OR SCHEDULE 40 PVC.
5. USE BUTYL RUBBER TO SEAL BETWEEN SECTIONS AND TOP AND USE NON-SHRINK GROUT AT ALL PENETRATIONS.
6. LOCATE RISER UNDER MANHOLE COVER TO ENABLE VISUAL INSPECTION OF RISER PIPE.
7. CLEANING SHALL BE PERFORMED AS NECESSARY TO ASSURE PROPER FUNCTIONING OF THE GREASE TRAP. WASTE MATERIAL REMOVED FROM GREASE TRAP SHALL BE DISPOSED OF PROPERLY: I.E.: NOT INTO SANITARY SEWER.
8. TWO-CHAMBER GREASE TRAP IS SHOWN; SINGLE CHAMBER UNIT IS SIMILAR AND MAY ALSO BE AN APPROVED OPTION.



The Good Life

**CITY OF TEGA CAY
LAND DEVELOPMENT
STANDARDS**

**TWO-CHAMBER
GREASE TRAP
(INTERCEPTOR)**

SCALE: N.T.S.
REVISION DATE: 10/3/16